



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip: Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 7120
 Test Date 9/11/2019

CSDG Unit # 2 4 5 6

Engine Make/ Model: Cummins GTA855B
 Engine Spec/ Serial: 55100283
 Unit Make/ Model: Katolight N250FJZ4
 Unit Spec/ Serial: LM223679P-44192

Voltage: 480
 Amperage: 375 @.8 PF / 301 @ 1.0 PF
 Kilowatts: 250
 Power Factor: 0.8

	5 Min.	15 Min.	20 Min.	25 Min.	30 Min	45 Min.	1 Hour	Cool down
Eng Hours	194.6	194.9	195.1	195.3	195.4	195.6	195.7	195.7
Hertz/Cycles	60.25	60.25	60.25	60.25	60.25	60.25	60.25	60.5
AC Voltage PH1	482	482	482	482	482	482	482	482
PH2	482	482	482	482	482	482	482	482
PH3	482	482	482	482	482	482	482	482
Amperage PH1	60	120	180	240	270	300	300	0
PH2	60	120	180	240	270	300	300	0
PH3	60	120	180	240	270	300	300	0
Kilowatts	50	100	150	200	225	250	250	0
Oil Pressure	80	80	75	75	70	70	70	70
Oil Temperature	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Coolant Temperature	165°F	175°F	180°F	185°F	188°F	188°F	188°F	180°F
Exhaust Temperature	1000°F	1050°F	1075°F	1100°F	1100°F	1125°F	1150°F	1000°F
DC Voltage	24	25	26	26	26	26	26	26
Natural Gas Pressure	11"	11"	11"	11"	11"	11"	11"	11"
Ambient Temperature	86°F	86°F	86°F	86°F	86°F	86°F	86°F	86°F

Technician Signature: Michael R. Biehl Sr.

Customer Signature: _____