



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 7027
 Test Date 2019.04.04

Engine Make/ Model: Cummins QSX15G9 NR2
 Engine Spec/ Serial: 79348984
 Unit Make/ Model: Cummins/ Onan
 Unit Spec/ Serial: DFEJ-7447363

Voltage: 480
 Amperage: 677
 Kilowatts: 450
 Power Factor 0.8

	15 Min	30 Min	45 Min	1 Hour	1 Hr 15 Min	1 Hr 30 Min	1 Hr 45 Min	2 Hours	Cool Down
Eng Hours	96								
Hertz/Cycles	60	60	60	60	60	60	60	60	60
Voltage PH1	480	479	479	479	479	479	479	479	480
PH2	481	482	481	481	482	481	481	482	482
PH3	481	480	480	480	480	481	480	480	480
Amperage PH1	190	352	540	542	543	542	541	542	0
PH2	189	351	542	541	541	540	542	543	0
PH3	188	350	541	542	541	543	540	540	0
Kilowatts	157	292	449	450	450	450	449	450	0
Oil Pressure	41	39	38	38	38	38	37	38	40
Oil Temperature									
Coolant Temperature	179°F	180°F	180°F	180°F	180°F	180°F	180°F	179°F	178°F
Man Vac./Press. L/B									
Man Vac./Press. R/B									
L/B Exhaust Temp									
R/B Exhaust Temp									
Exhaust Temperature									
DC Voltage									
Natural Gas Pressure									
Diesel Fuel Level									
Room Temperature									
Ambient Temperature	31°F	31°F	31°F	32°F	32°F	32°F	32°F	32°F	32°F

Technician Signature: _____

Customer Signature: _____