



Customer: Central States Diesel Generators STK#2459  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7047  
 Test Date 4-8-2019

Engine Make/ Model: Cummins QSX15-G9  
 Engine Spec/ Serial: 79000813  
 Unit Make/ Model: 500DFEK-3055  
 Unit Spec/ Serial: A030461797

Voltage: 277/480  
 Amperage: 752  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	103	103	103	103	104	104
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	480	481	481	481
PH2	480	480	480	480	480	480
PH3	480	481	481	480	481	481
Amperage PH1	0	602	600	601	601	0
PH2	0	601	602	602	600	0
PH3	0	601	602	601	602	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	44	41	40	40	40	42
Oil Temperature						
Coolant Temperature	178°F	180°F	180°F	180°F	180°F	179°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.8	26.8	26.8	26.8	26.8	26.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	53°F	53°F	54°F	54°F	54°F	54°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_