



Customer: Central States Diesel Generators STK#2460
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7054
 Test Date 4-9-2019

Engine Make/ Model: Cummins 6CTA-8.3G
 Engine Spec/ Serial: 44247080
 Unit Make/ Model: ONAN 150DGFAL31987A
 Unit Spec/ Serial: F880136269

Voltage: 277/480
 Amperage: 226
 Kilowatts: 150
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	986.8	987	987.3	987.5	987.8	987.9
Hertz/Cycles	63.3	60.1	60.1	60.1	60.1	63.3
Voltage PH1	486	472	473	472	472	486
PH2	487	474	474	474	474	487
PH3	487	474	473	474	474	487
Amperage PH1	0	185	184	185	184	0
PH2	0	184	185	184	184	0
PH3	0	181	182	181	181	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	45	42	40	40	40	42
Oil Temperature						
Coolant Temperature	180°F	182°F	181°F	182°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.4	27.4	27.4	27.4	27.4	27.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	56°F	56°F	56°F	56°F	57°F	57°F

Technician Signature: _____

Customer Signature: _____