



Customer: Central States Diesel Generators STK#2463
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7527
 Test Date 6-10-2019

Engine Make/ Model: Cummins LTA-10G1
 Engine Spec/ Serial: 34765628
 Unit Make/ Model: Cummins 200DFAA
 Unit Spec/ Serial: Spec.74790E S/N C950571176

Voltage: 277/480
 Amperage: 241
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	487.9	488.1	488.4	488.6	488.9	489
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	481	481	480	481	480	481
PH3	481	481	482	481	481	481
Amperage PH1	0	240	239	240	240	0
PH2	0	239	241	240	239	0
PH3	0	241	242	242	241	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	43	36	35	35	35	37
Oil Temperature	190°F	203°F	205°F	205°F	205°F	195°F
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	73°F	73°F	73°F	73°F	73°F	73°F

Technician Signature: Randy Pool

Customer Signature: _____