



Customer: Central States Diesel Generators STK#2465
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: _____
 Test Date 6/17/2019

Engine Make/ Model: Ford WSG1068
 Engine Spec/ Serial: E172A0511123100747
 Unit Make/ Model: Cummins GGHH-1329192
 Unit Spec/ Serial: Spec. L S/N F130516985

Voltage: 277/480
 Amperage: 120
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	144.7	144.9	145.2	145.4	145.7	145.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	481	481	480
PH2	480	480	480	480	480	480
PH3	480	480	481	480	480	480
Amperage PH1	0	65	66	65	66	0
PH2	0	66	65	66	65	0
PH3	0	66	66	66	66	0
Kilowatts	0	55	55	55	55	0
Oil Pressure	77	74	73	72	72	74
Oil Temperature						
Coolant Temperature	185°F	201°F	200°F	201°F	200°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	71°F	71°F	71°F	71°F	72°F	72°F

Technician Signature: _____

Customer Signature: _____