



Customer: Central States Diesel Generators STK#2470
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7495
 Test Date 7/22/2019

Engine Make/ Model: Caterpillar 3512
 Engine Spec/ Serial: 24703149
 Unit Make/ Model: Caterpillar 3512
 Unit Spec/ Serial: 24703149

Voltage: 277/480
 Amperage: 1880
 Kilowatts: 1250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	43.2	43.4	43.7	43.9	44.2	44.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	481	480	480
PH2	481	480	481	480	481	481
PH3	481	480	481	480	480	481
Amperage PH1	0	1505	1503	1504	1505	0
PH2	0	1504	1504	1504	1504	0
PH3	0	1504	1502	1503	1503	0
Kilowatts	0	1250	1250	1250	1250	0
Oil Pressure	70	64	64	64	64	67
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	70°F	71°F	71°F

Technician Signature: _____

Customer Signature: _____