



Customer: Central States Diesel Generators STK#2471
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7494
 Test Date 7/10/2019

Engine Make/ Model: Caterpillar 3512
 Engine Spec/ Serial: 3YF00462
 Unit Make/ Model: Caterpillar 3512
 Unit Spec/ Serial: 3YF00462

Voltage: 277/480
 Amperage: 2256
 Kilowatts: 1500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	875.8	876	876.3	876.5	876.8	876.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	481	480	480
PH2	481	480	481	480	481	481
PH3	481	480	481	480	480	481
Amperage PH1	0	1804	1804	1804	1803	0
PH2	0	1804	1804	1805	1807	0
PH3	0	1806	1805	1805	1806	0
Kilowatts	0	1500	1500	1500	1500	0
Oil Pressure	60	56	55	55	55	58
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25.2	25.2	25.2	25.2	25.2	25.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	85°F	85°F	85°F	86°F	86°F	86°F

Technician Signature: _____

Customer Signature: _____