



Customer: Central States Diesel Generators STK#2477
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8215
 Test Date 10-17-19

Engine Make/ Model: Volvo Penta TAD1353GE
 Engine Spec/ Serial: 2013308047 VP-181670
 Unit Make/ Model: Generac SD0400
 Unit Spec/ Serial: 2114887

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	139	139.3	139.5	139.8	140	140.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	480	480	480	480	480	480
Amperage PH1	0	481	482	481	482	0
PH2	0	481	482	481	481	0
PH3	0	482	481	482	481	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	80	72	71	70	70	72
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	180°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	44°F	44°F	45°F	45°F	45°F	45°F

Technician Signature: Randy Pool

Customer Signature: _____