



Customer: Central States Diesel Generators STK#2482
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7459
 Test Date 6-17-2019

Engine Make/ Model: Caterpillar 3408
 Engine Spec/ Serial: 78Z01608
 Unit Make/ Model: Caterpillar 3408
 Unit Spec/ Serial: 78Z01608

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1554	1554	1554	1555	1555	1555
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	482	481	480	480
PH2	481	480	481	481	480	480
PH3	481	481	481	480	481	480
Amperage PH1	0	480	481	480	480	0
PH2	0	480	479	481	483	0
PH3	0	483	481	482	480	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	73	70	68	68	68	70
Oil Temperature						
Coolant Temperature	180°F	200°F	200°F	200°F	200°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.2	26.2	26.2	26.2	26.2	26.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	64°F	64°F	65°F	65°F	65°F	65°F

Technician Signature: Randy Pool

Customer Signature: _____