



Customer: Central States Diesel Generators STK#2483  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7460  
 Test Date 6-17-2019

Engine Make/ Model: Caterpillar 3408  
 Engine Spec/ Serial: 78Z01706  
 Unit Make/ Model: Caterpillar 3408  
 Unit Spec/ Serial: 78Z01706

Voltage: 277/480  
 Amperage: 481  
 Kilowatts: 400  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1596	1596	1596	1597	1597	1597
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	479	479	480	480
PH2	480	480	480	480	480	480
PH3	480	481	481	480	481	480
Amperage PH1	0	480	481	481	481	0
PH2	0	482	482	481	481	0
PH3	0	481	482	483	483	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	80	77	76	75	75	77
Oil Temperature	180°F	200°F	200°F	200°F	200°F	183°F
Coolant Temperature	180°F	195°F	195°F	195°F	195°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25.6	25.6	25.6	25.6	25.6	25.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	59°F	59°F	60°F	60°F	60°F	61°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_