



Customer: Central States Diesel Generators STK#2484
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7325
 Test Date 5-20-2019

Engine Make/ Model: Cummins LTA-10G1
 Engine Spec/ Serial: 35020115
 Unit Make/ Model: Cummins DFAC-4489099
 Unit Spec/ Serial: J000161955

Voltage: 120/208
 Amperage: 694
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	43.5	43.8	44	44.3	44.5	44.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	209	208	208	208
PH2	208	208	208	208	208	208
PH3	208	209	209	208	208	208
Amperage PH1	0	693	694	693	694	0
PH2	0	695	693	694	694	0
PH3	0	694	694	694	693	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	41	38	37	37	37	39
Oil Temperature						
Coolant Temperature	180°F	188°F	189°F	189°F	190°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	54°F	54°F	55°F	55°F	55°F	55°F

Technician Signature: _____

Customer Signature: _____