



Customer: Central States Diesel Generators STK#2486
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7316
 Test Date 6-13-2019

Engine Make/ Model: Cummins QST30-G1
 Engine Spec/ Serial: 37189609
 Unit Make/ Model: Cummins 750DFHA-362
 Unit Spec/ Serial: Spec.D S/N J990001060

Voltage: 277/480
 Amperage: 902
 Kilowatts: 750
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	19260.5	19260.7	19261	19261.2	19261.5	19261.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	487	486	487	487	486	487
PH2	486	487	487	486	487	486
PH3	487	487	486	486	487	487
Amperage PH1	0	890	892	892	893	0
PH2	0	891	890	892	891	0
PH3	0	892	892	891	890	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	58	52	51	51	50	53
Oil Temperature	190°F	195°F	195°F	196°F	195°F	192°F
Coolant Temperature	175°F	177°F	178°F	178°F	178°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	24.4*	24.4*	24.4*	24.4*	24.4*	24.4*
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	71°F	71°F	71°F	71°F	71°F

Technician Signature: Randy Pool

Customer Signature: _____