



Customer: Central States Diesel Generators STK#2487
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7315
 Test Date 5-20-2019

Engine Make/ Model: Cummins QST30-G5-NRI
 Engine Spec/ Serial: 37195630
 Unit Make/ Model: Cummins 1000DFHD-1186
 Unit Spec/ Serial: K000169176

Voltage: 277/480
 Amperage: 1203
 Kilowatts: 1000
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	126.7	126.9	127.2	127.4	127.7	127.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	481	480	480	480
PH3	479	479	479	480	479	479
Amperage PH1	0	1205	1204	1205	1206	0
PH2	0	1204	1205	1204	1205	0
PH3	0	1205	1204	1203	1203	0
Kilowatts	0	1000	1000	1000	1000	0
Oil Pressure	60	53	51	51	51	53
Oil Temperature	190°F	199°F	199°F	199°F	199°F	192°F
Coolant Temperature	170°F	172°F	171°F	172°F	172°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	48°F	48°F	49°F	49°F	49°F	49°F

Technician Signature: _____

Customer Signature: _____