



Customer: Central States Diesel Generators STK#2491
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7533
 Test Date 8-8-2019

Engine Make/ Model: International GCD325
 Engine Spec/ Serial: WS4486N146112
 Unit Make/ Model: Olympian D200P3
 Unit Spec/ Serial: OLY00000CNNS01539

Voltage: 277/480
 Amperage: 240
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1006.3	1006.5	1006.8	1007	1007.3	1007.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	482	481	481	481
PH2	481	481	481	481	482	481
PH3	482	481	482	481	481	482
Amperage PH1	0	240	241	240	240	0
PH2	0	239	240	241	241	0
PH3	0	241	240	241	241	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	65	56	55	54	54	57
Oil Temperature						
Coolant Temperature	180°F	195°F	195°F	195°F	195°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25.6	25.6	25.6	25.6	25.6	25.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	82°F	83°F	83°F	83°F	84°F	84°F

Technician Signature: Randy Pool

Customer Signature: _____