



Customer: Central States Diesel Generators STK#2492
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7534
 Test Date 6-28-2019

Engine Make/ Model: Caterpillar C15
 Engine Spec/ Serial: FSE01006
 Unit Make/ Model: Caterpillar C15
 Unit Spec/ Serial: C5E00772

Voltage: 277/480
 Amperage: 601
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	25.8	26	26.3	26.5	26.8	26.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	480	481	480
PH2	481	481	480	481	481	481
PH3	480	480	481	480	481	480
Amperage PH1	0	600	603	600	603	0
PH2	0	602	602	604	602	0
PH3	0	603	601	602	599	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	70	65	63	63	63	65
Oil Temperature						
Coolant Temperature	180°F	188°F	189°F	189°F	189°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.1	27.1	27.1	27.1	27.1	27.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	84°F	84°F	84°F	84°F	85°F	85°F

Technician Signature: _____

Customer Signature: _____