



Customer: Central States Diesel Generators STK#2497  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7535  
 Test Date 8-2-2019

Engine Make/ Model: Caterpillar 3516  
 Engine Spec/ Serial: 4XF00267  
 Unit Make/ Model: Caterpillar 3516  
 Unit Spec/ Serial: 4XF00267

Voltage: 277/480  
 Amperage: 2406  
 Kilowatts: 2000 TEST@1800  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	806.7	806.9	807.2	807.4	807.7	807.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	481	480	480
PH2	481	480	481	480	481	481
PH3	481	480	481	480	480	481
Amperage PH1	0	2165	2165	2168	2167	0
PH2	0	2167	2164	2164	2169	0
PH3	0	2166	2166	2165	2163	0
Kilowatts	0	1800	1800	1800	1800	0
Oil Pressure	70	55	52	52	52	55
Oil Temperature						
Coolant Temperature	180°F	182°F	182°F	182°F	182°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	65°F	65°F	65°F	66°F	66°F	66°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_