



Customer: Central States Diesel Generators STK#2499
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9246
 Test Date 5-13-20

Engine Make/ Model: John Deere 6059TF003
 Engine Spec/ Serial: CD6059T366055
 Unit Make/ Model: Kohler 100ROZJ
 Unit Spec/ Serial: 397814

Voltage: 277/480
 Amperage: 120
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	681.3	681.5	681.8	682	682.3	682.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	481	481
PH2	481	481	481	481	481	481
PH3	480	480	480	480	480	480
Amperage PH1	0	120	119	120	121	0
PH2	0	119	120	119	120	0
PH3	0	120	129	129	119	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	55	45	41	40	40	43
Oil Temperature						
Coolant Temperature	180°F	188°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.8	14.8	14.8	14.8	14.8	14.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	45°F	45°F	45°F	46°F	46°F	46°F

Technician Signature: Randy Pool

Customer Signature: _____