



Customer: Central States Diesel Generators STK#2500  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8659  
 Test Date 1-20-20

Engine Make/ Model: John Deere 6135HF485  
 Engine Spec/ Serial: RG6135L000390  
 Unit Make/ Model: Baldor 350KW  
 Unit Spec/ Serial: P0704020003

Voltage: 277/480  
 Amperage: 421  
 Kilowatts: 350  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4012.2	4012.5	4012.7	4013	4013.2	4013.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	482	483	482	482	482
PH2	483	483	483	483	483	483
PH3	482	482	482	482	482	482
Amperage PH1	0	419	420	419	420	0
PH2	0	418	418	418	418	0
PH3	0	420	419	420	419	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	55	52	52	52	52	54
Oil Temperature						
Coolant Temperature	165°F	167°F	167°F	167°F	167°F	166°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	19°F	19°F	19°F	19°F	19°F	19°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_