



Customer: Central States Diesel Generators STK#2500
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7607
 Test Date 7-22-2019

Engine Make/ Model: John Deere 6135HF485
 Engine Spec/ Serial: RG6135L000390
 Unit Make/ Model: TS400T
 Unit Spec/ Serial: P0704020003

Voltage: 277/480
 Amperage: 526
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4011.1	4011.3	4011.6	4011.8	4012.1	4012.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	478	478	479	478	479
PH2	480	478	478	477	478	480
PH3	480	479	478	479	478	480
Amperage PH1	0	423	422	423	423	0
PH2	0	422	423	422	421	0
PH3	0	423	423	424	424	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	56	52	50	50	50	52
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	62°F	62°F	63°F	63°F	63°F	63°F

Technician Signature: _____

Customer Signature: _____