



Customer: Central States Diesel Generators STK#2503
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 9469
 Test Date 7-9-2020

Engine Make/ Model: Volvo TAD 720 GE
 Engine Spec/ Serial: 53 10263269
 Unit Make/ Model: AIRMAN SDG150S
 Unit Spec/ Serial: 1726A60158

Voltage: 277/480
 Amperage: 181/199
 Kilowatts: 120 Prime/132 StdBy
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	6497.7	6498	6498.2	6498.5	6498.7	6498.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483
PH2	482	482	482	482	482	482
PH3	482	482	482	482	482	482
Amperage PH1	0	157	158	157	158	0
PH2	0	159	158	158	157	0
PH3	0	158	157	158	158	0
Kilowatts	0	132	132	132	132	0
Oil Pressure	55	48	42	42	42	48
Oil Temperature						
Coolant Temperature	185°F	209°F	209°F	210°F	210°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.3	14.3	14.3	14.3	14.3	14.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	78°F	78°F	78°F	79°F	79°F	79°F

Technician Signature: Randy Pool

Customer Signature: _____