



Customer: Central States Diesel Generators STK#2504  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7609  
 Test Date 7-10-2019

Engine Make/ Model: John Deere 4024TF281  
 Engine Spec/ Serial: PE4024R057298  
 Unit Make/ Model: Generac SD0030  
 Unit Spec/ Serial: 2113122

Voltage: 277/480  
 Amperage: 45  
 Kilowatts: 30  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	79.1	79.4	79.6	79.8	80.1	80.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	481	480	480	481
PH2	482	480	481	480	480	482
PH3	481	480	481	480	480	481
Amperage PH1	0	36	36	36	35	0
PH2	0	36	35	37	36	0
PH3	0	37	36	35	36	0
Kilowatts	0	30	30	30	30	0
Oil Pressure	75	42	68	68	68	70
Oil Temperature						
Coolant Temperature	165°F	173°F	173°F	173°F	173°F	165°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.3	14.3	14.3	14.3	14.3	14.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	87°F	87°F	87°F	87°F	88°F	88°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_