



Customer: Central States Diesel Generators STK#2505
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7606
 Test Date 7-15-2019

Engine Make/ Model: Cummins QSL9-G2 NR3
 Engine Spec/ Serial: 46862577
 Unit Make/ Model: Cummins DSHAC-7075967
 Unit Spec/ Serial: D080170951

Voltage: 277/480
 Amperage: 301
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	29	29.2	29.5	29.7	30	30.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	240	241	240	240	0
PH2	0	241	240	241	240	0
PH3	0	240	240	240	241	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	65	61	58	57	57	59
Oil Temperature						
Coolant Temperature	180°F	190°F	190°F	190°F	190°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	78°F	78°F	79°F	79°F

Technician Signature: _____

Customer Signature: _____