



Customer: Central States Diesel Generators STK#2506  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7605  
 Test Date 7-15-2019

Engine Make/ Model: Cummins NTA855-G5  
 Engine Spec/ Serial: 11823592  
 Unit Make/ Model: Cummins 400DFCE  
 Unit Spec/ Serial: J960621676

Voltage: 277/480  
 Amperage: 602  
 Kilowatts: 400  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	346	346.2	346.5	346.7	347	347.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	482	480	480	480	480
Amperage PH1	0	480	482	480	480	0
PH2	0	481	482	483	482	0
PH3	0	482	481	482	483	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	52	48	42	42	42	44
Oil Temperature						
Coolant Temperature	185°F	193°F	193°F	194°F	194°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.3	27.3	27.3	27.3	27.3	27.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	82°F	82°F	82°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_