



Customer: Central States Diesel Generators STK#2507  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7611  
 Test Date 8-5-2019

Engine Make/ Model: Cummins LTA10-G1  
 Engine Spec/ Serial: 35015754  
 Unit Make/ Model: Cummins DFAB-4486331  
 Unit Spec/ Serial: 1000147348

Voltage: 120/208  
 Amperage: 638  
 Kilowatts: 230  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1032.8	1033	1033.3	1033.5	1033.8	1033.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	210	210	210	210
PH2	209	209	209	209	209	209
PH3	210	210	210	210	210	210
Amperage PH1	0	636	635	635	636	0
PH2	0	634	636	635	634	0
PH3	0	635	634	636	635	0
Kilowatts	0	230	230	230	230	0
Oil Pressure	55	50	48	48	48	49
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.5	27.5	27.5	27.5	27.5	27.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	83°F	83°F	84°F	84°F	84°F	84°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_