



Customer: Central States Diesel Generators STK#2511  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7728  
 Test Date 8-5-2019

Engine Make/ Model: Cummins QSL9-G2-NR3  
 Engine Spec/ Serial: 73741728  
 Unit Make/ Model: Cummins DSHAD-1415929  
 Unit Spec/ Serial: Spec. F S/N I140749096

Voltage: 277/480  
 Amperage: 277  
 Kilowatts: 230  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	73	73.2	73.5	73.7	74	74.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	481	481	481	481	481	481
Amperage PH1	0	276	276	277	276	0
PH2	0	277	276	276	276	0
PH3	0	276	277	277	277	0
Kilowatts	0	230	230	230	230	0
Oil Pressure	65	61	60	60	60	63
Oil Temperature						
Coolant Temperature	185°F	194°F	194°F	194°F	194°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.2	14.2	14.2	14.2	14.2	14.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	85°F	85°F	86°F	86°F	86°F	86°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_