



Customer: Central States Diesel Generators STK#2514
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7812
 Test Date 8-13-2019

Engine Make/ Model: Volvo TAD1631GE
 Engine Spec/ Serial: 2160050969
 Unit Make/ Model: Kohler 500ROZD4
 Unit Spec/ Serial: Spec. GM30674-GA1 S/N 2007779

Voltage: 277/480
 Amperage: 775
 Kilowatts: 515
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	597.7	598	598.2	598.5	598.7	598.8
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	481	480	480	480
PH2	481	481	479	479	479	481
PH3	480	480	480	480	480	480
Amperage PH1	0	621	620	621	620	0
PH2	0	620	621	620	621	0
PH3	0	620	620	621	621	0
Kilowatts	0	515	515	515	515	0
Oil Pressure	80	75	74	73	73	75
Oil Temperature						
Coolant Temperature	180°F	196°F	197°F	197°F	197°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	82°F	82°F	83°F	83°F	83°F	83°F

Technician Signature: Randy Pool

Customer Signature: _____