



Customer: Central States Diesel Generators STK#2516
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7754
 Test Date 8-2-2019

Engine Make/ Model: John Deere 4045HF285
 Engine Spec/ Serial: PE4045L237869
 Unit Make/ Model:
 Unit Spec/ Serial:

Voltage: 277/480
 Amperage: 96
 Kilowatts: 80
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1.9	2.1	2.4	2.6	2.9	3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	484	484	483	483
PH2	482	482	482	482	482	482
PH3	481	481	481	481	481	481
Amperage PH1	0	96	96	96	95	0
PH2	0	95	96	96	96	0
PH3	0	96	95	95	96	0
Kilowatts	0	80	80	80	80	0
Oil Pressure	54	48	46	45	45	48
Oil Temperature						
Coolant Temperature	180°F	186°F	186°F	186°F	186°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.4	13.4	13.4	13.4	13.4	13.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	80°F	80°F	80°F	80°F	81°F	81°F

Technician Signature: Randy Pool

Customer Signature: _____