



Customer: Central States Diesel Generators STK#2518
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7794
 Test Date 9-12-2019

Engine Make/ Model: GM 8.1L Nat. Gas
 Engine Spec/ Serial: 8P1L15708
 Unit Make/ Model: Caterpillar G125G1
 Unit Spec/ Serial: NGG00623

Voltage: 120/208
 Amperage: 347
 Kilowatts: 125 test @ 60 on LP
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	0.2	0.4	0.7	0.9	1.2	1.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	206	207	206	206	207	206
PH2	206	206	206	207	206	206
PH3	206	206	206	207	206	206
Amperage PH1	0	170	169	168	168	0
PH2	0	168	169	170	169	0
PH3	0	170	170	169	170	0
Kilowatts	0	60	60	60	60	0
Oil Pressure	60	52	50	50	50	53
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.6	13.6	13.6	13.6	13.6	13.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	66°F	66°F	66°F	66°F	66°F	66°F

Technician Signature: Randy Pool

Customer Signature: _____