



Customer: Central States Diesel Generators STK#2519
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7795
 Test Date 8-5-2019

Engine Make/ Model: Cummins QSM11-G2
 Engine Spec/ Serial: 35158496
 Unit Make/ Model: Cummins 275DQAE-5849
 Unit Spec/ Serial: Spec. E S/N D060909604

Voltage: 277/480
 Amperage: 331
 Kilowatts: 275
 Power Factor 0.8

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 59.3 | 59.5 | 59.8 | 60 | 60.3 | 60.4 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 480 | 480 | 480 | 480 | 480 | 480 |
| PH2 | 480 | 479 | 479 | 479 | 479 | 480 |
| PH3 | 480 | 480 | 480 | 480 | 480 | 480 |
| Amperage PH1 | 0 | 332 | 332 | 331 | 330 | 0 |
| PH2 | 0 | 331 | 331 | 330 | 331 | 0 |
| PH3 | 0 | 330 | 331 | 332 | 333 | 0 |
| Kilowatts | 0 | 275 | 275 | 275 | 275 | 0 |
| Oil Pressure | 44 | 38 | 36 | 36 | 36 | 39 |
| Oil Temperature | 190°F | 217°F | 217°F | 217°F | 217°F | 195°F |
| Coolant Temperature | 185°F | 190°F | 190°F | 190°F | 190°F | 185°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 28 | 28 | 28 | 28 | 28 | 28 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 87°F | 87°F | 88°F | 88°F | 88°F | 88°F |

Technician Signature: Randy Pool

Customer Signature: _____