



Customer: Central States Diesel Generators STK#2522
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7811
 Test Date 8-20-2019

Engine Make/ Model: Cummins VTA28-G5
 Engine Spec/ Serial: 25296250
 Unit Make/ Model: Synergy 600CA
 Unit Spec/ Serial: 98-207493-1

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	37.4	37.6	37.9	38.1	38.4	38.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	479	480	479	479	480	479
PH3	479	479	479	479	479	479
Amperage PH1	0	722	723	724	722	0
PH2	0	723	722	722	723	0
PH3	0	724	724	724	724	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	70	59	56	55	55	60
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	76°F	76°F	77°F	77°F	77°F	77°F

Technician Signature: Randy Pool

Customer Signature: _____