



Customer: Central States Diesel Generators STK#2523
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7810
 Test Date 8-21-2019

Engine Make/ Model: Mitsubishi S12A2-Y1PTA-1
 Engine Spec/ Serial: 24559
 Unit Make/ Model: Kohler 800REOZM
 Unit Spec/ Serial: 2089854

Voltage: 277/480
 Amperage: 975
 Kilowatts: 810
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	233	233.2	233.5	233.8	234	234.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	478	479	479	479
PH2	478	478	478	479	478	479
PH3	478	479	479	479	478	479
Amperage PH1	0	977	543	544	543	0
PH2	0	978	544	543	544	0
PH3	0	980	543	542	543	0
Kilowatts	0	810	450	450	450	0
Oil Pressure	90	85	85	85	85	85
Oil Temperature						
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	80°F	80°F	80°F	81°F	81°F	81°F

Technician Signature: Randy Pool

Customer Signature: _____