



Customer: Central States Diesel Generators STK#2526
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7813
 Test Date 8-27-2019

Engine Make/ Model: Cummins QSL9-G2 NR3
 Engine Spec/ Serial: 46954398
 Unit Make/ Model: Cummins DSHAD-7274459
 Unit Spec/ Serial: J080217264

Voltage: 277/480
 Amperage: 277
 Kilowatts: 230
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	313.3	313.5	313.8	314	314.3	314.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	486	486	485	486	486	486
PH2	486	486	487	486	486	486
PH3	485	486	485	485	486	485
Amperage PH1	0	274	274	275	274	0
PH2	0	273	274	273	273	0
PH3	0	274	273	274	274	0
Kilowatts	0	230	230	230	230	0
Oil Pressure	60	55	54	54	54	56
Oil Temperature						
Coolant Temperature	180°F	190°F	191°F	191°F	191°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	78°F	78°F	78°F	78°F	79°F	79°F

Technician Signature: _____

Customer Signature: _____