



Customer: Central States Diesel Generators STK#2529  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 7990  
 Test Date 8-27-2019

Engine Make/ Model: Ford LSG-875I-6005-A  
 Engine Spec/ Serial: 16697-1-04-98  
 Unit Make/ Model: Cummins GGHC-4480031  
 Unit Spec/ Serial: E000100497

Voltage: 277/480  
 Amperage: 97  
 Kilowatts: 80  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	468	468.2	468.4	468.7	469	469.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	480	481	481
PH3	480	480	481	480	480	480
Amperage PH1	0	97	97	96	97	0
PH2	0	96	96	97	96	0
PH3	0	97	97	97	97	0
Kilowatts	0	80	80	80	80	0
Oil Pressure	79	77	75	75	75	77
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.5	13.5	13.5	13.5	13.5	13.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	81°F	81°F	82°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_