



Customer: CEES
 Address: 530 Santa Rosa Dr,
 City/ State/ Zip Des Plaines, IL 60018
 Contact: Mike B.
 Phone: 630-834-6000 Ext.121

R#: 7493
 Test Date 7-10-2019

Engine Make/ Model: FORD LSG-875I-6003-C
 Engine Spec/ Serial: 19167
 Unit Make/ Model: ONAN 100ENTXL28191A
 Unit Spec/ Serial: L880188217

Voltage: 120/208
 Amperage: 277
 Kilowatts: 100 Test at 50
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1265.2	1265.5	1265.7	1266	1266.2	1266.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	211	210	211	210	211	211
PH2	211	211	210	211	210	211
PH3	205	205	205	206	205	205
Amperage PH1	0	138	137	138	138	0
PH2	0	138	137	139	138	0
PH3	0	137	138	137	136	0
Kilowatts	0	50	50	50	50	0
Oil Pressure	65	61	60	60	60	62
Oil Temperature						
Coolant Temperature	175°F	177°F	177°F	177°F	176°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.4	13.4	13.4	13.4	13.4	13.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	70°F	70°F	70°F	70°F	70°F	71°F

Technician Signature: Randy Pool

Customer Signature: _____