



Customer: Central States Diesel Generators STK#2533
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7928
 Test Date 9-4-2019

Engine Make/ Model: Perkins 2206D-E13TAG
 Engine Spec/ Serial: TGBF5081 U15563W
 Unit Make/ Model: AKSA APD-EPAP300
 Unit Spec/ Serial: U15563W

Voltage: 277/480
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	672.5	672.7	673	673.2	673.5	673.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483
PH2	484	484	484	484	484	484
PH3	483	483	483	483	483	483
Amperage PH1	0	358	359	358	359	0
PH2	0	361	360	358	358	0
PH3	0	359	358	361	360	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	85	80	78	78	78	80
Oil Temperature						
Coolant Temperature	185°F	195°F	197°F	196°F	196°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	64°F	64°F	64°F	64°F	64°F	64°F

Technician Signature: Randy Pool

Customer Signature: _____