



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 8008
 Test Date 2020.02.03

Engine Make/ Model: PSI,GM-8.1L
 Engine Spec/ Serial: N/A, 8P1L20735
 Unit Make/ Model: Onan, GGLB-547137
 Unit Spec/ Serial: G, E090000558

Voltage: 240
 Amperage: 451
 Kilowatts: 150
 Power Factor 1.0

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	272.3	273.3	
Hertz/Cycles	60	60	60	60	60	
Voltage PH1	209	209	209	209	209	
PH2	209	209	209	209	209	
PH3	209	209	209	209	209	
Amperage PH1	411	411	411	411	411	
PH2	412	412	412	412	412	
PH3	412	412	412	412	412	
Kilowatts	149	149	149	149	149	0
Oil Pressure	54	43	41	41	41	
Oil Temperature						
Coolant Temperature	200°F	210°F	211°F	210°F	210°F	
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	43°F	43°F	43°F	43°F	43°F	

Technician Signature: Jaime Merlo

Customer Signature: _____