



Customer: Central States Diesel Generators STK#2535
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 8007
 Test Date 9-10-2019

Engine Make/ Model: Cummins QST30-G5
 Engine Spec/ Serial: 37220219
 Unit Make/ Model: Cummins DFHD-5729430
 Unit Spec/ Serial: K050851171

Voltage: 277/480
 Amperage: 1504
 Kilowatts: 1000
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	706.1	706.3	706.6	706.8	707.1	707.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	481	481	481	481	481
PH3	480	480	480	480	480	480
Amperage PH1	0	1204	1203	1203	1204	0
PH2	0	1204	1204	1204	1203	0
PH3	0	1203	1203	1203	1204	0
Kilowatts	0	1000	1000	1000	1000	0
Oil Pressure	64	54	52	51	51	55
Oil Temperature	195°F	210°F	210°F	210°F	210°F	200°F
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25.8	25.8	25.8	25.8	25.8	25.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	82°F	82°F	82°F

Technician Signature: Randy Pool

Customer Signature: _____