



Customer: Central States Diesel Generators STK#2536
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7926
 Test Date 9-24-2019

Engine Make/ Model: Caterpillar C9
 Engine Spec/ Serial: S/N: S9L03658 ARR#: 259-1808
 Unit Make/ Model: Caterpillar
 Unit Spec/ Serial: S/N: G5A04647

Voltage: 277/480
 Amperage: 301
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	77.4	77.6	77.9	78.1	78.4	78.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	481	480	481
PH2	480	481	481	481	481	480
PH3	480	480	480	480	480	480
Amperage PH1	0	240	241	240	241	0
PH2	0	241	240	241	240	0
PH3	0	240	241	241	241	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	60	54	53	53	53	54
Oil Temperature						
Coolant Temperature	180°F	187°F	187°F	187°F	187°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	61°F	61°F	61°F	61°F	62°F	62°F

Technician Signature: _____

Customer Signature: _____