



Customer: Central States Diesel Generators STK#2537
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8785
 Test Date 2-12-20

Engine Make/ Model: Cummins KTA38-G1
 Engine Spec/ Serial: 33121796
 Unit Make/ Model: Cummins 750DFJA
 Unit Spec/ Serial: E920471056

Voltage: 277/480
 Amperage: 902
 Kilowatts: 750
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2437.2	2437.4	2437.7	2437.9	2438.2	2438.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	482	483	483	483
PH2	481	481	480	481	481	481
PH3	481	481	482	481	481	481
Amperage PH1	0	900	900	900	900	0
PH2	0	902	902	900	901	0
PH3	0	902	901	901	900	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	90	82	80	80	80	82
Oil Temperature						
Coolant Temperature	170°F	170°F	170°F	170°F	170°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	21°F	21°F	21°F	21°F	21°F	21°F

Technician Signature: Randy Pool

Customer Signature: _____