



Customer: Central States Diesel Generators STK#2540
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 8006
 Test Date 9-12-2019

Engine Make/ Model: Cummins GTA8.3G1
 Engine Spec/ Serial: 46068458
 Unit Make/ Model: Cummins GGKB-4957141
 Unit Spec/ Serial: D010223669

Voltage: 277/480
 Amperage: 188
 Kilowatts: 125
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	676.9	677.1	677.4	677.6	677.9	678
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	484	484	484	484	484	484
PH2	485	484	485	485	485	484
PH3	484	485	484	484	485	484
Amperage PH1	0	149	150	149	149	0
PH2	0	149	149	150	150	0
PH3	0	150	149	149	149	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	67	65	64	64	63	65
Oil Temperature						
Coolant Temperature	180°F	186°F	187°F	187°F	187°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.5	13.5	13.5	13.5	13.5	13.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	67°F	67°F	67°F	67°F	66°F	66°F

Technician Signature: Randy Pool

Customer Signature: _____