



Customer: Central States Diesel Generators STK#2542
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 8010
 Test Date 9-17-2019

Engine Make/ Model: MTU Detroit Diesel
 Engine Spec/ Serial: 06R1024367
 Unit Make/ Model: MTU Detroit Diesel 350RXC6DT3
 Unit Spec/ Serial: 307307-1-1-0309

Voltage: 277/480
 Amperage: 421
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	142.2	142.4	142.7	142.9	143.2	143.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	479	479	479	479	480
PH3	480	480	480	480	480	480
Amperage PH1	0	422	421	422	421	0
PH2	0	421	422	421	422	0
PH3	0	421	421	421	421	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	57	52	50	50	50	52
Oil Temperature						
Coolant Temperature	185°F	192°F	194°F	194°F	194°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.4	27.4	27.4	27.4	27.4	27.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	64°F	64°F	64°F	65°F	65°F	65°F

Technician Signature: Randy Pool

Customer Signature: _____