



Customer: Central States Diesel Generators STK#2543  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 8036  
 Test Date 9-24-2019

Engine Make/ Model: Cummins VTA28-G5  
 Engine Spec/ Serial: 25164198  
 Unit Make/ Model: 600DFGB  
 Unit Spec/ Serial: B890212247

Voltage: 277/480  
 Amperage: 722  
 Kilowatts: 600  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	277.6	277.8	278.1	278.3	278.6	278.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483
PH2	484	484	484	484	484	484
PH3	483	483	483	483	483	483
Amperage PH1	0	717	718	717	717	0
PH2	0	718	716	718	716	0
PH3	0	718	717	719	718	0
Kilowatts	0	600	600	600	600	0
Oil Pressure	70	68	67	67	67	69
Oil Temperature						
Coolant Temperature	185°F	197°F	197°F	198°F	197°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	72°F	73°F	73°F	73°F	73°F	74°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_