



Customer: Central States Diesel Generators STK#2546
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 8015
 Test Date 9-17-2019

Engine Make/ Model: Detroit Diesel SERIES 60 4-Cycle
 Engine Spec/ Serial: 06R0652320
 Unit Make/ Model: Kohler 350REOZD
 Unit Spec/ Serial: 709764

Voltage: 277/480
 Amperage: 427
 Kilowatts: 355
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	392.3	392.5	392.8	393	393.3	393.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	480	481	480	481
PH2	480	481	481	481	481	480
PH3	480	479	479	479	479	480
Amperage PH1	0	427	428	427	428	0
PH2	0	428	428	428	427	0
PH3	0	428	427	428	428	0
Kilowatts	0	355	355	355	355	0
Oil Pressure	60	54	53	53	53	55
Oil Temperature						
Coolant Temperature	186°F	192°F	192°F	192°F	192°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	82°F	82°F	82°F

Technician Signature: Randy Pool

Customer Signature: _____