



Customer: Central States Diesel Generators STK#2550  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8081  
 Test Date 10-17-19

Engine Make/ Model: Perkins 2332/1800  
 Engine Spec/ Serial: YD51130\*U824880L\*  
 Unit Make/ Model: Olympian D125P1  
 Unit Spec/ Serial: OLY00000PNATO1045

Voltage: 120/240  
 Amperage: 521  
 Kilowatts: 125  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	42.2	42.5	42.7	43	43.2	43.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	241	241	241	241	241	241
PH2	0	0	0	0	0	0
PH3	0	0	0	0	0	0
Amperage PH1	0	521	520	520	521	0
PH2	0	522	520	521	521	0
PH3	0	0	0	0	0	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	90	82	75	70	65	70
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	44°F	44°F	45°F	45°F	45°F	46°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_