



Customer: Central States Diesel Generators STK#2551  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8184  
 Test Date 12-3-19

Engine Make/ Model: Caterpillar 3208  
 Engine Spec/ Serial: 5YF01309  
 Unit Make/ Model: Caterpillar 3208  
 Unit Spec/ Serial: 5YF01309

Voltage: 277/480  
 Amperage: 240  
 Kilowatts: 200  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1333	1333	1334	1334	1334	1334
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	484	484	483	484	484
PH2	483	484	483	483	483	483
PH3	484	484	483	484	483	484
Amperage PH1	0	239	240	240	239	0
PH2	0	240	240	240	240	0
PH3	0	240	239	238	239	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	72	66	65	65	65	67
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	181°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	37°F	37°F	38°F	38°F	38°F	38°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_