



Customer: Central States Diesel Generators STK#2554
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8349
 Test Date 11-26-19

Engine Make/ Model: Doosan P222LE
 Engine Spec/ Serial: EAYOA00191
 Unit Make/ Model: Generac MD0600
 Unit Spec/ Serial: 2090162

Voltage: 277/480
 Amperage: 722
 Kilowatts: 600
 Power Factor 0.8

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 478 | 478.2 | 478.5 | 478.7 | 479 | 479.1 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 479 | 479 | 479 | 479 | 479 | 480 |
| PH2 | 480 | 480 | 480 | 480 | 480 | 480 |
| PH3 | 479 | 479 | 479 | 480 | 479 | 479 |
| Amperage PH1 | 0 | 724 | 724 | 724 | 723 | 0 |
| PH2 | 0 | 723 | 723 | 722 | 722 | 0 |
| PH3 | 0 | 724 | 723 | 723 | 724 | 0 |
| Kilowatts | 0 | 300 | 600 | 600 | 600 | 0 |
| Oil Pressure | 100 | 95 | 93 | 93 | 93 | 94 |
| Oil Temperature | | | | | | |
| Coolant Temperature | 178°F | 179°F | 180°F | 179°F | 180°F | 178°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 28.9 | 28.9 | 28.9 | 28.9 | 28.9 | 28.9 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 44°F | 44°F | 44°F | 44°F | 44°F | 44°F |

Technician Signature: _____

Customer Signature: _____