



Customer: Central States Diesel Generators STK#2555

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 8348

Test Date 11-8-19

Engine Make/ Model: Doosan P222LE

Engine Spec/ Serial: EAYOA600815

Voltage: 277/480

Amperage: 722

Unit Make/ Model: Generac MD0600

Kilowatts: 600

Unit Spec/ Serial: 2095126

Power Factor 0.8

|                      | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours            | 267.2  | 267.5   | 267.7   | 268     | 268.2  | 268.3     |
| Hertz/Cycles         | 60     | 60      | 60      | 60      | 60     | 60        |
| Voltage PH1          | 480    | 480     | 480     | 480     | 480    | 480       |
| PH2                  | 480    | 480     | 480     | 480     | 480    | 480       |
| PH3                  | 482    | 482     | 482     | 482     | 482    | 482       |
| Amperage PH1         | 0      | 722     | 721     | 722     | 721    | 0         |
| PH2                  | 0      | 721     | 722     | 721     | 722    | 0         |
| PH3                  | 0      | 721     | 721     | 721     | 721    | 0         |
| Kilowatts            | 0      | 300     | 600     | 600     | 600    | 0         |
| Oil Pressure         | 105    | 95      | 90      | 90      | 90     | 92        |
| Oil Temperature      |        |         |         |         |        |           |
| Coolant Temperature  | 170°F  | 170°F   | 170°F   | 170°F   | 170°F  | 170°F     |
| Man Vac./Press. L/B  |        |         |         |         |        |           |
| Man Vac./Press. R/B  |        |         |         |         |        |           |
| L/B Exhaust Temp     |        |         |         |         |        |           |
| R/B Exhaust Temp     |        |         |         |         |        |           |
| Exhaust Temperature  |        |         |         |         |        |           |
| DC Voltage           | 28.8   | 28.8    | 28.8    | 28.8    | 28.8   | 28.8      |
| Natural Gas Pressure |        |         |         |         |        |           |
| Diesel Fuel Level    |        |         |         |         |        |           |
| Room Temperature     |        |         |         |         |        |           |
| Ambient Temperature  | 18°F   | 18°F    | 18°F    | 19°F    | 19°F   | 19°F      |

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_