



Customer: Central States Diesel Generators STK#2556
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8183
 Test Date 11-26-19

Engine Make/ Model: Caterpillar 3456
 Engine Spec/ Serial: 7WG00687
 Unit Make/ Model: Caterpillar 3456
 Unit Spec/ Serial: CAT00000TCCB00621

Voltage: 277/480
 Amperage: 561
 Kilowatts: 466
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	586	586	586	587	587	587
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	560	561	560	561	0
PH2	0	561	562	561	562	0
PH3	0	561	560	560	560	0
Kilowatts	0	466	466	466	466	0
Oil Pressure	68	64	62	62	62	63
Oil Temperature						
Coolant Temperature	180°F	190°F	190°F	190°F	190°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	34°F	34°F	34°F	35°F	35°F	35°F

Technician Signature: Randy Pool

Customer Signature: _____