



Customer: Central States Diesel Generators STK#2557
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8218
 Test Date 1-20-20

Engine Make/ Model: John Deere 5030HF285
 Engine Spec/ Serial: PE5030L013799
 Unit Make/ Model: Generac 11232460100
 Unit Spec/ Serial: 2103720

Voltage: 277/480
 Amperage: 72
 Kilowatts: 60
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	312	312.2	312.5	312.7	313	313.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	489	489	489	489	489	489
PH2	492	492	491	492	492	492
PH3	489	489	490	489	489	489
Amperage PH1	0	70	70	70	70	0
PH2	0	70	70	70	70	0
PH3	0	71	71	71	71	0
Kilowatts	0	60	60	60	60	0
Oil Pressure	55	53	53	53	53	54
Oil Temperature						
Coolant Temperature	120°F	120°F	120°F	120°F	120°F	120°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.7	14.7	14.7	14.7	14.7	14.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	7°F	7°F	7°F	8°F	8°F	8°F

Technician Signature: Randy Pool

Customer Signature: _____